

SECTION 085653

SECURITY WINDOWS (BR 100 Sash Window)

PART 1 – GENERAL

1.1 SECTION INCLUDES

- A. Aluminum bullet resistant interior window.

1.2 RELATED DOCUMENTS

- A. Drawings, and general provisions of the Contract.

1.3 RELATED SECTIONS

- A. Section 088856 – Ballistic-Resistant Glazing
- B. Section 013300 – Submittal Procedures

1.4 DEFINITIONS

- A. AAMA: American Architectural Manufacturers Association
- B. ASTM: American Society for Testing and Materials.
- C. UL: Underwriters Laboratory

1.5 PERFORMANCE REQUIREMENTS

- A. Ballistics-Resistance Performance Requirements: Provide security window frames identical to those tested for compliance with requirements indicated, and as follows.
 - 1. Security window and window assemblies will meet or exceed the requirements of UL 752 Level III.
 - 2. Testing is conducted by H.P. White Laboratory or an approved equivalent independent testing laboratory.
 - 4. Proof of certification is available upon request.
 - 5. Testing conforms to Underwriters Laboratory UL 752 Ballistic Standards.

1.6 SUBMITTALS

- A. Shop Drawings: Provide elevations indicating rough openings requirements and details for field installed assemblies.

- B. Qualification Data: Submit qualifications verifying years of experience; include list of completed jobs having similar scope of work, identified by name, location, date contact names and phone numbers.
- C. Product Data: Provide manufacture's data sheets on all products used.
- D. Selection Samples: Provide two product samples for each finish specified.
- E. Verification Samples: Provide sample for product specified, minimum size 6 inches (150 mm) square, and representing actual product.

1.7 QUALITY ASSURANCE

- A. Provide test reports from a nationally recognized testing laboratory certifying the UL rating on product.
- B. Drawings and specifications are based on Action Bullet Resistant's Model BR 100 Sash Window.
- C. Installer Qualifications: An experienced installer who has completed similar design, material and extent to this project.
- D. Manufacture's facility will be made available during production for inspection of windows by customer's representative to ensure compliance of products with drawings and specifications.

1.8 DELIVERY, STORAGE AND HANDLING

- A. Product will be securely crated to prevent damage during shipping. Each crate will be identified by door number and/or elevation. Packing list will identify all contents of crate.
- B. Verify contents of crate within five days of receipt. If crates are to be stored for long periods due to construction delays, place in a dry warehouse with moderate temperatures.
- C. When handling crates use forklift or pallet jack.

1.9 PROJECT CONDITIONS

- A. Field Measurements: Verify security window openings by field measurements before fabrication and indicate measurements on Shop Drawings.
- B. Established Dimensions: Where field measurements cannot be made without delaying the work, establish openings and proceed with fabrication without field measurements using held dimensions. Coordinate wall construction to ensure that actual openings dimensions correspond with held dimensions.

1.10 WARRANTY

- A. Contractor warrants installation for a period of one year and assumes full responsibility for installation of the system, which includes the window, window system, glass, anchorage, setting, sealing, flashing, etc, as it relates to air, water and structural adequacy as required in the shop drawings and specifications.
- B. Manufacture warrants products for period of one year from the date of customer receipt.

PART 2 – PRODUCTS

2.1 MANUFACTURE

- A. Acceptable Manufacturer: Action Bullet Resistant, Inc., located at 263 Union Blvd. West Islip, NY 11795; Toll Free Tel. 800-962-8088; Tel 631-422-0888; Fax Tel 631-422-4498; Email info@actionbullet.com; Web www.actionbullet.com

2.2 PRODUCT TYPE

- A. Security windows available in a fixed window.

2.3 MATERIAL

- A. Aluminum Extrusions: Aluminum alloy and temper – 6005-T5. Ultimate tensile strength of 37.7 ksi, and shear strength of 29.7 ksi.
- B. Silicone: Structural silicone GE SCS 1000 complies with ASTM-C-920-05.
- C. Glass and Glazing: See Section 088856.
- D. Setting blocks – Neoprene 80-85 durometer ASTM-D-2000

2.4 FABRICATION

- A. Frames are fully fabricated and shipped to customer for field installation.
- B. Fasteners where exposed will be stainless or other non-corrosive material.
- C. Window frames are 1 ½” x 2 3/8” with 1/4” minimum wall thickness.
- D. Window to have tight hairline joints where the horizontal mullion meets with vertical mullions.
- E. Glazing pocket to be 1” deep for proper bite.

2.5 FINISH

- A. Exposed surfaces to be free of scratches and other serious blemishes. Anodic finishes are electrolytically deposited Class II finish. Manufactures standard finish:

